

- KEY:**
- 1 22,500 litre fire supply tank
 - 2 22,500 litre fire supply tank
 - 3 67,500 litre tank-Linked at base-Overflow to Tank 7
 - 4 67,500 litre tank-Linked at base-Overflow to Tank 7
 - 5 67,500 litre tank-Linked at base-Overflow to Tank 7
 - 6 67,500 litre tank-Linked at base-Overflow to Tank 7
 - 7 67,500 litre tank-Linked at base-Overflow to Tank 7
 - 8 30,000 litre tank for irrigation
 - 9 30,000 litre tank for irrigation
 - 10 30,000 litre tank for irrigation
 - 11 9,000 litre Silt Trap
 - 12 30,000 litre tank detention tank
 - 13 30,000 litre water supply tank for A3

- Piped Services Trench: Combined services trench for WW/SW discharge and supply drains. Refer Deane Consultants Wastewater/Stormwater report
- Roofwater: 150mm diameter SW supply from roof to RW tanks
- Waste water: 100mm diameter WW drain @ 1:80 fall to septic effluent tank
- Water supply: 63mm diameter potable pressure pipe to supply buildings
- Surface water + Ground Water: 225mm diameter (unless otherwise specified) surface area runoff


- Area of Wastewater Primary effluent discharge field
 - Area of Wastewater Reserve effluent discharge field
- Refer Deane Consultants Stormwater Report and TP58 discharge consent for specification and detail of WW/SW systems

25.08.21-REVISED DRIVEWAY
 14.05.21-UPDATED TO REFLECT WW/SW PLANS
 19.04.21-REMOVED HELIPAD/PAVILION POSITION

project **PANETIKI**
 address Address - 20 Omaha Block Access Road
 title

PROPOSED SERVICES PLAN

scale 1:1000 @ A1 size
 date 25/08/21
 RESOURCE CONSENT
 sheet **TP.9**



gra
 geoff richards architects ltd
 1 Reef st devonport 0626
 p.o. box 32-556 devonport 0744
 auckland new zealand
 ph 09 446 0800

contractor to verify all dimensions on site