

# Mason Clinic Plan Change

## Waitemata District Health Board

Reference: 508877

Revision: 05

2021-04-29

**aurecon**

*Bringing ideas  
to life*

# Document control record

Document prepared by:

**Aurecon New Zealand Limited**

Level 4, 139 Carlton Gore Road  
Newmarket Auckland 1023  
PO Box 9762  
Newmarket Auckland 1149  
New Zealand

**T** +64 9 520 6019

**F** +64 9 524 7815



**E** auckland@aurecongroup.com

**W** aurecongroup.com

A person using Aurecon documents or data accepts the risk of:

- a) Using the documents or data in electronic form without requesting and checking them for accuracy against the original hard copy version.
- b) Using the documents or data for any purpose not agreed to in writing by Aurecon.

Document control						aurecon
<b>Report title</b>		Document title				
<b>Document code</b>		04	<b>Project number</b>		508877	
<b>File path</b>		Aurecon Group\508877 - Mason Clinic Auckland Unitary Plan - Reports				
<b>Client</b>		Waitemata District Health Board				
<b>Client contact</b>		<b>Client reference</b>				
<b>Rev</b>	<b>Date</b>	<b>Revision details/status</b>	<b>Author</b>	<b>Reviewer</b>	<b>Verifier (if required)</b>	<b>Approver</b>
04	2021-04-06	Update Version	Alistair Osborne & Eric Zhang	Albert Ho & Michaela Wilson	Margaret Cobeldick	N Black
05	2021-04-29	Update Version	Alistair Osborne & Eric Zhang	Albert Ho & Michaela Wilson	Margaret Cobeldick	N Black
<b>Current revision</b>		<b>05</b>				

Approval			
<b>Author signature</b>		<b>Approver signature</b>	
			
<b>Name</b>	Alistair Osborne	<b>Name</b>	N Black
<b>Title</b>	Senior Water Modeller	<b>Title</b>	Associate

# Contents

- 1 Objective ..... 1**
  - 1.1 Introduction..... 1
  - 1.2 Proposed Plan Change..... 1
  - 1.3 Site Description and Topology..... 2
    - 1.3.1 Site Description..... 2
    - 1.3.2 Site Topography..... 3
  
- 2 Wastewater ..... 3**
  - 2.1 Existing Wastewater Drainage ..... 3
  - 2.2 Proposed Connections ..... 4
  - 2.3 Capacity Assessment..... 4
  
- 3 Water Supply ..... 7**
  - 3.1 Existing Water Supply Network ..... 7
  - 3.2 Proposed Servicing ..... 7
  - 3.3 Capacity Assessment..... 7
  
- 4 Utility Services ..... 9**
  - 4.1 Power and Gas ..... 9
  - 4.2 Communications ..... 9
  
- 5 Stormwater ..... 10**
  - 5.1 Purpose..... 10
    - 5.1.1 Wairaka Streams and Overland Flow Paths ..... 11
    - 5.1.2 Flood Plain..... 12
    - 5.1.3 Stormwater Management ..... 13
  - 5.2 Stormwater Infrastructure..... 14
    - 5.2.1 Existing Stormwater Drainage ..... 14
    - 5.2.2 Proposed Stormwater Drainage..... 14
    - 5.2.3 Proposed stormwater quality treatment ..... 14
  - 5.3 Summary ..... 15

## Appendices

- Appendix A - Proposed Wastewater & Stormwater Network
- Appendix B – Development application form
- Appendix C – Meeting minutes
- Appendix D – Upstream flow and capacity check
- Appendix E – Beca proposed services drawings
- Appendix F – Hydrant testing result
- Appendix G– Existing Stormwater and Wastewater Utilities Plan
- Appendix H – Watercare Assessment Report 2021

## Figures

Figure 1: Site Extents/Boundary .....	2
Figure 2: Existing public wastewater network (extracted from Auckland Council GIS) .....	3
Figure 3: Existing Mason Clinic private wastewater network .....	4
Figure 4: Existing stormwater network draining through Mason Clinic .....	11
Figure 5: Wairaka Stream corridor and OLFP alignments .....	12
Figure 6: Existing Wairaka Stream OLFP (source: Auckland Council GEOMaps) .....	13

## Tables

- Table 1: Total flow for facility scenarios
- Table 2: Hydrant testing results
- Table 3: Total water demand for facility scenarios

# 1 Objective

## 1.1 Introduction

This report supports the proposed plan change application by the Waitemata District Health Board (WDHB) for the Mason Clinic site, Auckland on the basis of infrastructure. It assesses the infrastructure services required to support the change of zoning from Business Mixed Use zone to Special Purpose - Healthcare Facility and Hospital zone under the Auckland Unitary Plan (Operative in Part) (AUP:OIP), and changes to the planning provisions in the Wairaka Precinct, including by extending the boundaries of Sub-precinct A and amending several standards.

The existing Mason Clinic Site is located at 81A Carrington Road, Pt Chevalier (Mason Clinic Site). The Mason Clinic provides forensic mental health services and intellectual disability services for the northern part of the North Island (from Taupo northwards). WDHB has recently acquired a combined 2.8ha of land to the north (Northern Site) and south (Southern Site) of the existing Mason Clinic Site. The acquisition of this land will enable the WDHB to plan for the overall development of this site to both enable the replacement of older, unfit buildings, and secondly to expand and intensify the facilities into the future due to increased demand.

The purpose of this report is to:

- assess the appropriateness of the proposed plan change from an infrastructure perspective (i.e. assess whether the Mason Clinic Site is and/or can be adequately serviced), and
- assess the effects of the proposed plan change, relative to the status quo.

## 1.2 Proposed Plan Change

The proposed plan change better facilitates the development of the Mason Clinic Site by: re-zoning the Northern Site and Southern Site from *Business - Mixed Use* to *Special Purpose - Healthcare Facility and Hospital*, to reflect the nature and needs of the Mason Clinic activity.

- amending the boundaries of Sub-Precinct A of the Wairaka Precinct to include the whole Plan Change Area.
- making adjustments to the objectives, policies and rules in the Wairaka Precinct to both better enable the development of the Mason Clinic Site, and to manage that development relative to other nearby development which is expected to occur in the future.

The purpose of the proposed plan change is to enable the efficient development and use of healthcare activities located at Mason Clinic. It is important to demonstrate that the impact of the proposed plan change will be negligible in regards to the proposed scale or intensity of the development that is currently possible at the Mason Clinic Site, or that any changes can be adequately serviced by infrastructure.

The acquisition of the new land by WDHB and the proposed plan change will allow the Mason Clinic to develop and expand more efficiently and effectively to support the growing needs of the community. The WDHB's intention is to grow the capacity of the Mason Clinic from the current 111 beds to 246 beds, and an associated increase in staff.

The proposed plan change is in alignment with development guidance and requirements set out in the AUP:OIP, where it does not amend to maximum impervious area for the Plan Change Site, and ultimately will have a negligible impact on the relevant infrastructure and surrounding environment.

This report will confirm the impact of the proposed Plan Change on the infrastructure servicing at the Mason Clinic Site including the following:

- The location and capacity of infrastructure;

- The extent to which stormwater, wastewater, water supply, electricity and telecommunication infrastructure needs to be provided to adequately service the nature and staging of anticipated development within the application area; and
- The extent to which stormwater management methods that utilise low impact stormwater design principles and improved water quality systems should be provided.

It is noted that whilst the proposed plan change will allow for the development, the subsequent staging of the development will still need to go through the resource consent and engineering plan approval stages with the relevant local authorities to approve the detailed design. This includes the specific connections and load demands on infrastructure. These requirements are typical of any proposed development and are in-line with the current zoning requirements.

## 1.3 Site Description and Topology

### 1.3.1 Site Description

The Existing Mason Clinic Site, the Northern Site and the Southern Site are all within the Wairaka Precinct of the AUP:OIP. The Existing Mason Clinic Site is within Sub-precinct A, which specifically provides for the Mason Clinic. The Northern Site and the Southern Site are currently vacant but are zoned Business – Mixed Use. The Southern Site is identified as ‘Key Open Space (private)’ in Wairaka Precinct Plan 1. Access to all sites is off Carrington Road, via the currently-private road network within the wider Wairaka Precinct.



Figure 1: Site Extents/Boundary

### 1.3.2 Site Topography

The existing Mason Clinic Site sits at the east of the new Waterview tunnel in Point Chevalier. Oakley Creek is located along the western boundary of the site with the ground sloping gently from RL 10m, west to RL 5m near the creek. At the northern extent of the Northern Site, the land slopes up to RL 16m at the boundary.

## 2 Wastewater

### 2.1 Existing Wastewater Drainage

The existing public wastewater network in the Mason Clinic site comprises of a Watercare 1050mm dia. transmission pipe which passes from Mt Albert from the east to a junction within the southern section of the Mason Clinic and then directs south, as well as 375mm and 300mm dia. wastewater reticulation mains as shown in Figure 2. The 375mm dia. wastewater main carries the wastewater load generated with the suburb of Pt Chevalier to the north and discharges into the 1050mm dia. transmission pipe. This pipe is currently located beneath a number of existing buildings within the Mason Clinic Site. The 300mm pipe carries flows from Waterview from the west, and also discharges into the transmission pipeline at the same connection point. All wastewater then flows southwards from the connection point within the Mason Clinic Site.




Figure 2: Existing public wastewater network (extracted from Auckland Council GIS)

The existing private wastewater network within the Mason Clinic Site currently discharges to the 375mm main owned by Watercare Services (WSL). Figure 3 shows the existing private and public wastewater network within the site.






Figure 3: Existing Mason Clinic private wastewater network

Note: Plan based on Maunsell 'Site & Services Plan', 2006

## 2.2 Proposed Connections

To facilitate the development and expansion of the Mason Clinic, it is proposed to utilise the existing connections on site to convey wastewater flows from the site to the discharge into the Watercare 1050 dia. transmission pipeline.

The existing connections are sufficiently sized to enable the development to proceed without any major works needed.

As stated above, the resource consent and engineering plan approval processes will manage the detailed design of any physical works to the existing and proposed wastewater services, including if any existing pipes need to be realigned within or around the site, and where buildings are proposed above public services.

## 2.3 Capacity Assessment

The re-development of Mason Clinic results in an increase in the patient capacity and number of staff. Based on the information provided by Klein Architects Limited, the number of patients that can be facilitated at the larger Mason Clinic will be 246. To facilitate this increased patient capacity, WDHb predicts that the staff roster will expand to a size of 407. The total flow generated from the facility has been calculated based on the staff and patient numbers as per the Watercare Code of Practice and is shown in Table 1.



Initial consultation with Watercare has been undertaken and the development assessment form has been completed and submitted to Watercare on 21<sup>st</sup> July 2020 with a response received on 08 March 2021 (refer to Appendix H).

Watercare noted there are existing capacity constraints in the local area which would need to be mitigated by the developer through extensions or upgrades to the network. They also confirmed that the upstream existing pipes (375mm) will need a capacity assessment completed to inform the proposed network for the development. However as noted in the Watercare assessment report these works would be undertaken during the resource consent process following the approval of the proposed plan change. This demonstrates that the impact of the development forming the proposed plan change on the wastewater network will be similar to the current zoning of the land as the constraints noted above are existing and external to the Mason Clinic site. The Watercare response therefore confirms that the proposed plan change would have no adverse effects on the wastewater network and the servicing of the site would be completed following the standard detail design and consenting process.

Watercare also indicated that as part of a wider development, the Unitec site near Mason Clinic is also to be developed and the outcomes and timing of this may impact the final capacity. Based on Aurecon's knowledge of the site, Unitec's development is downstream of this network and is unlikely to impact the Mason Clinic upstream development.

The peak wastewater discharge was calculated to form a basis for comparison between what could potentially be developed under the current planning provisions (Mixed-Use Zone), and what development will be enabled under the proposed plan change. We have assumed that the mixed-use zone would be developed into mainly residential dwellings, using a dwelling density ratio of 94 to 113 dwellings per hectare, which is consistent with the development intensity which is planned by MHUD for the adjoining land within the Wairaka Precinct. The planning Assessment of Environmental Effects also explains the type and scale of development which is anticipated by the current zoning, and this explanation has been relied on.

Under the assumptions on the zoning above, two scenarios of alternative development were assessed and compared against the development enabled by the plan change:

- Development Scenario 1 – assess a gross dwelling density of 94 to 113 dwellings per hectare, across both the Northern Site and the Southern Site (2.84 ha total) on the basis of the underlying zoning
- Development Scenario 2 – assess a gross dwelling density of 94 to 113 dwellings per hectare to the Northern Site only (1.64 ha), and assume the south land will be open space only on the basis that it is identified as Key Open Space in the Wairaka Precinct.

	Dwellings	Equivalent Population	Peak Dry Weather Flow (PDWF) <sup>1</sup> l/s	Peak Wet Weather Flow (PWWF) l/s
Development Scenario 1	321	963	6.0	30.1
Development Scenario 2	186	558	3.5	17.4
Proposed Plan Change and development	NA	653	2.9	14.3

**Table 1: Total flow for facility scenarios**

The Peak Dry Weather Flow (PDWF) is defined as the most likely peak wastewater flow in the pipe during a normal day. It exhibits a regular pattern of usage with morning and evening peaks relating to water usage for toilets, showers, baths, washing and other household activities.

<sup>1</sup>Discharge rate based on occupancy and peaking factors were applied in alignment with the Watercare Code of Practice, Section 5.3.5, Tables 5.1.1 and 5.1.5.

The Peak Wet Weather Flow (PWWF) is obtained by adding inflow and infiltration to the peak dry weather flow. Wet weather flows include sewage flows and runoff that infiltrate into the wastewater systems during a storm event. Wet weather flows also include groundwater flows that enter through defective pipe joints, connections and/or manhole walls.

The difference in the calculations of the wastewater flows based on the zoning for the proposed plan change (Healthcare) and the current (Mixed-Use ie residential) reflects the different water use activities for each zone. Healthcare facilities, whilst can have a higher population do not allow for the same activities that generate wastewater flows that residential zones. This is noted above which shows the proposed plan change has a higher population than Development Scenario 2, but results in a lower flow rate.

Based on the analysis, the projected wastewater discharge as allowed with maximum development under the proposed plan change, is less than that under current zoning of the Northern and Southern sites (both under Development Scenarios 1 and 2).

As such, it is concluded from a wastewater infrastructure loading perspective, that the proposed plan change will result in lesser utilisation of existing infrastructure capacity. Furthermore, network capacity up to the proposed maximum discharge has been confirmed with Watercare.

# 3 Water Supply

## 3.1 Existing Water Supply Network

There is an existing private 150mm dia. potable and firefighting ring main within the Mason Clinic Site that is supplied from a 150mm dia. watermain in Great North Road. It is also noted that there is a transmission watermain located in Carrington Road (450AC) and a larger local line located in Great North Road (200CI) providing redundancy and resilience to the area.

## 3.2 Proposed Servicing

It is proposed to retain the connection to the 150mm dia. watermain in Great North Road for servicing the existing Mason Clinic site. As noted above, the existing public watermain in Carrington Road provide sufficient servicing capacity for future development of the site. Therefore, servicing of future developments under the plan change or current zoning is anticipated to only require private service connections which are considered minor in nature..

## 3.3 Capacity Assessment

Hydrant testing has been carried out by PBS Fire Data in October 2017 on the 150mm dia. ring main within the Mason Clinic site. A summary of the results is shown in Table 2 with more details in Appendix F.

Static Pressure (kPa)	Average Residual Pressure (kPa)	Average Flow (L/s)
750	519	37

Table 2: Hydrant testing results

According to Table 1 of New Zealand Fire Service Firefighting Water Supplies Code of Practice<sup>2</sup>, buildings with crowd activities of more than 100 people with low fire loads such as medical consulting rooms and offices fall under the category of FHC2. By assuming the floor area of the largest firecell is between 0-199 m<sup>2</sup>, the fire water classification has been assumed as FW3 with the following specification:

- The required flow within a distance of 135m is 25 L/s
- The required additional flow within a distance of 270m is 25 L/s
- The minimum running pressure in the water main should not be less than 100kPa

The fire water classification will be confirmed by the Fire Engineers during the design phase. Further field testing will also be undertaken to confirm the capacity of the existing water network.

According to Watercare COP, the design pressure for the main Mason Clinic watermain shall be between 250KPa to 800kPa.

- The peak water consumption was calculated on the Basis of Development Scenarios 1 and 2, described above.

<sup>2</sup> New Zealand Fire Service Firefighting Water Supplies Code of Practice, SNZ PAS 4509:2008

	Dwellings	Equivalent Population	Average Day Demand (ADD) <sup>3</sup> l/s	Average Day Peak Hour Demand (PHD) l/s	Peak Day Peak Hour Demand (PDD) l/s
Development Scenario 1	321	963	2.5	6.1	12.3
Development Scenario 2	186	558	1.4	3.6	7.1
Proposed plan change and development	NA	653	2.0	5.1	10.1

**Table 3: Total water demand for facility scenarios**

Based on the analysis, the projected water consumption as allowed with maximum development under the proposed plan change is less than that in Development Scenario 1.

Following on from the Watercare Assessment report (Appendix H) received on March 8<sup>th</sup>, 2021, Watercare have confirmed that the proposed demand that will be generated by the proposed level of development enabled by the plan change can be supplied from the local water supply network in the area.

As such, it is concluded from a potable water infrastructure supply perspective, that the proposed plan change will result in similar or lesser utilisation of existing infrastructure capacity than the current planning provisions. Furthermore, network capacity up to the proposed peak day peak hour demand has been confirmed with Watercare.

<sup>3</sup> Consumption rate based on occupancy and peaking factors were applied in alignment with The Auckland Code of Practice for Land Development and Subdivision, Chapter 6, Section 6.3.5.3.

## 4 Utility Services

### 4.1 Power and Gas

The current Mason Clinic site is serviced by both power and gas utilities which also service the rest of the Wairaka Precinct site and surrounding areas. As with all new proposed developments, Vector will be engaged to coordinate and design any additional supplementary infrastructure required to support demand requirements of development. The current zoning requirements allow for development, therefore any increase in demand or servicing will be achieved by utilising the existing network.

The Wairaka Precinct is intended to be intensively redeveloped, and power services are likely to be comprehensively upgraded as required, to service this development as well as the Mason Clinic development. However, with the current bulk and network infrastructure in the area for both electricity and gas for service and supply, any works to support the plan change development would be of a minor nature and in line with the status quo for the area as it stands.

### 4.2 Communications

The current Mason Clinic Site is serviced by telecommunications utilities that also supply the rest of the original Unitec site and catchment with connections to the current infrastructure network in the area. As with all new proposed developments, Chorus will be engaged to coordinate and design any additional supplementary infrastructure required to support demand requirements of development. The current zoning allows for development, therefore any increase in demand or servicing will be achieved by utilising the existing network.

With the current bulk and network infrastructure in the area for telecommunications service and supply, any works to support the plan change development would be of a minor nature and in line with the status quo for the area as it stands.

# 5 Stormwater

## 5.1 Purpose

The proposed plan change does not amend the maximum impervious area for the Plan Change Site (as per Standard I334.6.5 of the AUP:OIP).

The proposed plan change also does not seek to amend rules in the AUP:OIP relating to the management of stormwater discharges and construction of stormwater infrastructure. These rules will continue to apply to the Mason Clinic Site, and include:

- Rules and standards in Chapter E8 for the diversion and discharge of stormwater runoff from impervious areas onto or into land or into water or to the coastal marine area, which generally apply to stormwater discharges from new or redeveloped impervious areas which are not diverted to existing authorised stormwater networks
- Rules and standards in Chapter E9 for the development of new or redevelopment of existing high contaminant generating carparks, which require the treatment of stormwater discharges from exposed carparks
- Rules and standards in Chapter E26 for the construction and use of stormwater pipes and outfall structures on or under land
- Rules and standards in Chapter E3 for the construction of structures in the beds of rivers or streams, and the associated bed disturbance or depositing any substance, reclamation, diversion of water and incidental damming of water

There is a difference in the AUP:OIP provisions between the current Mixed Use Zone and the proposed Special Purpose – Healthcare Facility and Hospital zone in regard to the definition of riparian yard. A riparian yard is defined as 10m from the edge of all permanent and intermittent streams in the ‘Business - Mixed Use Zone’, whereas in the ‘Special Purpose - Healthcare Facility and Hospital Zone’ the riparian yard is defined as 5m from the edge of streams.

The overall management of stormwater within the Mason Clinic Site is not impacted by the proposed plan change (with exception to the riparian margin definition described above which has no stormwater conveyance implications). The WDHB is currently involved in a separate process to have a Stormwater Management Plan prepared for the Wairaka Precinct, which includes the proposed development of the Plan Change Site. This will establish the stormwater management practices that will be employed for all stages of development, in respect of stormwater drainage and discharges, and the management of overland flow and surface flooding. This existing stormwater network in the Mason Clinic Site is shown in Figure 3.








Figure 5: Wairaka Stream corridor and OLFP alignments

### 5.1.2 Flood Plain

Based on the flood plain identified within Auckland Council's GEOMAPS, the 1% AEP with climate change rainfall event is predicted to exceed the capacity of the Wairaka Stream and OLFP intersecting the Mason Clinic site. As such, surface flooding is predicted as illustrated below.

The predicted flooding across the Mason Clinic site has implications on proposed building footprints and freeboard. This is notable for habitable floors, which are required to allow for 500mm freeboard from the 1% AEP flood depth, as per the Auckland Council Code of Practice for Stormwater, Chapter 4, Section 4.3.5.7.

Suitable management of the incoming Wairaka stream, and upstream catchment flows arriving via OLFP, can be completed during subsequent design, and is not impacted by the proposed plan change.






Figure 6: Existing Wairaka Stream OLFP (source: Auckland Council GEOMaps)

### 5.1.3 Stormwater Management

Management of stormwater conveyance across the Mason Clinic Site, and mitigation of surface flooding is required to be in alignment with the Auckland Council Storm Water Code of Practice (SWCoP<sup>4</sup>) and the AUP:OIP.

Overland flow paths are used to manage and mitigate any risks to sites, especially in areas where there are habitable buildings. In the event of natural hazards or events stormwater provisions set by the AUP:OIP are utilised to manage and mitigate the effects. Typically, this is done by using OLFP, detention basins, and swales to manage the rainfall runoff in a manner that results in reduced or no detrimental flooding impacts.

With future development, the capacity of the Wairaka Stream and OLFP intersecting the Mason Clinic site can be increased to better manage the predicted contributing runoff. Whereby the 1% AEP rainfall event flows can be contained within the defined channels, resulting in reduced surface flooding. As the discharge point for these flows are to the Oakley Stream, there is sufficient opportunity to allow for these events and development.

The proposal will more efficiently enable healthcare activities, with a zone which better recognises functional requirements of the activity. Given the nature of the plan change to a healthcare use, where the current and proposed zoning has the same limitations on maximum impervious area of 80% of the site, the runoff generated by the development will be consistent with the status quo and is able to be managed through the

<sup>4</sup> Auckland Council, 2015. *Code of Practice for Land Development and Subdivision. Chapter 4 – Stormwater. Version 2.*

standard design and resource consent processes. As a healthcare facility, the buildings will be considered habitable buildings therefore an appropriate freeboard will be required to mitigate and minimize risk to the development.

It is noted that the in-development Wairaka Precinct Stormwater Management Plan discusses the options and strategy to allow for the development of the entire catchment, including the Plan Change Site. This includes managing the risks and hazards and the AUP:OIP provisions. The Wairaka Precinct Stormwater Management Plan is not affected by the proposed plan change.

As part of due diligence for this plan change, a catchment analysis has been undertaken by Aurecon to outline the provisions required to demonstrate the viability of a development and the ability to meet the provisions of the Unitary plan. Where the existing and proposed zoning of the site has no notable stormwater management differences. It is shown that at a high level this is feasible with the final design to be confirmed during the development phases which is based on the current and future zones. The analysis can be made available subject to request.

It is therefore considered that the plan change, and subsequent development will not generate an increase to the potential adverse effects or risks of development of the subject land, and that these effects are able to be managed by the stormwater under the SWCoP and AUP through the standard resource consent processes.

## 5.2 Stormwater Infrastructure

### 5.2.1 Existing Stormwater Drainage

Existing stormwater primary drainage at the Mason Clinic site consists of five pipes conveying upstream flows across the site (Figure 4) with connections within the site for the collection of local runoff. Refer to the existing services plan in Appendix G for the location of the stormwater network within the existing site. Note that the existing services plan does not cover the entire extent of the Mason Clinic site and potentially there are further utilities not identified.

### 5.2.2 Proposed Stormwater Drainage

The nature of the long-term site development including demolition of the majority of existing buildings and construction of new ones means that the existing site drainage will become redundant being located in positions that are unable to service the new buildings. New stormwater drainage will be installed as part of the site construction works to convey primary drainage flows from the site to the discharge at Oakley Creek.

The exact design of this drainage is subject to the final building, road and civil design. However, in general the new drainage pipes will capture flows from the building roofs, carparks and internal road surfaces. All roads will have kerbs in place, and all stormwater from the paved surfaces will drain to stormwater catchpits located in appropriate low areas.

### 5.2.3 Proposed stormwater quality treatment

Stormwater quality treatment devices will be required for high contaminant generating car parks (>30 vehicles) under the AUP, E8 section for stormwater discharge. The level of treatment is dependent on the impervious area. The future detailed design of the stormwater treatment is therefore expected to comply with the following requirement:

- Primary (piped) drainage from the high contaminant generating carparks to be conveyed to a number of treatment rain-gardens, tree pits or similar bio-active filtration devices located throughout the site. Flows from the treatment units will return to the primary drainage system for discharge to Oakley Creek. Flows from areas of low contamination including roof surfaces and landscaping will be diverted directly to the Creek with no treatment.

The treatment flow rate will be agreed with Auckland Council, but will be less than the 10-year return period flow rate.

## 5.3 Summary

Assessments of the infrastructure services for the proposed plan change development shows that the Plan Change Area can be adequately serviced with the existing infrastructure that is available in the vicinity of the Mason Clinic. Fundamentally the existing infrastructure currently on site can support the scale and intensity of the development that will be enabled by the plan change, and the effects on these services have been demonstrated to be as per the status quo or result in lesser utilisation of existing infrastructure capacity.


Therefore, from an infrastructure perspective, the proposed plan change is assessed to be appropriately serviced and not introduce any adverse performance issues as compared to the status quo. Furthermore, it is demonstrated that the overall management of stormwater within the Mason Clinic Site, in terms of adhering to the AUP:OIP, is not impacted by the proposed plan change.

## Appendices

# Appendix A - Proposed Wastewater & Stormwater Network



- ⋯ - Proposed relocation of the existing 375mm wastewater line
- - Proposed private wastewater network
- - Existing public network
- - Connection to public network
- - Existing 375mm line to be relocated
- █ - Pipe bridging required



Connection to the existing network below Great North Road

Potential route for the relocation of existing 375mm line

The existing 375mm wastewater line is proposed to be relocated as a section of this line was built in 1926 and is approaching towards the end of its design life

All proposed network to be above 225mm in diameter as stated in Watercare's Wastewater COP chapter 5

Note: Areas indicated on the diagram are building GFAs. Where there are multiple figures shown for the same building, they represent floor area for each individual storey/level.

# Appendix B – Development application form

**Development Application Form –  
Water Supply/Wastewater Planning Assessment**

<b>Date of Application</b>	<b>30/07/2020</b>	
<b>Address of Development</b>	<b>Mason Clinic, 81a Carrington Road, Pt Chevalier</b>	
<b>Layout Plan of Proposed Development clearly showing:</b>	<ul style="list-style-type: none"> <li>• Aerial photograph</li> <li>• Road names</li> <li>• Boundary of development</li> <li>• Preferred point of connection to existing water supply and wastewater asset</li> </ul>	
	Refer to Appendices Appendix A: Site boundary Appendix B: Proposed wastewater and water connection locations with the existing network Appendix C: Wastewater calculation Appendix D: Existing 375mm capacity check Appendix E: Water calculation Appendix F: Hydrant testing result	
	<b>Description</b>	<b>Comment</b>
<b>Current Land Use</b>	Hospital facility at 81A Carrington Road. The northern site is currently unused land covered with grass and bush. The southern site currently has several garage/storage buildings.	<i>Residential (Single family dwellings) / Residential (Multi-unit dwellings) / Residential (Multi-storey apartment blocks) / Commercial / Industrial / Other (Please Specify)</i>
<b>Proposed Land Use</b>	The northern and southern site will be combined with 81a Carrington Road for an upgraded hospital facility with higher capacity	
<b>Total Development Area (Ha.)</b>	<i>6.8 Ha</i>	
<b>Number of Residential Households (Consent &amp; Ultimate)</b>	0	<i>E.g. 12- storey apartment building with 4 units per storey is 48 residential households.</i>

Refer to Water and Wastewater Code of Practice for Land Development and Subdivision Section 6 Water Supply

**Water Supply Development Assessment**

<b>Average and Peak Residential Demand (L/s)</b>		<i>Show calculations based on Watercare CoP</i>
<b>Average and Peak Non-Residential Demand (L/s)</b>	10.15 L/s	<i>Show calculations based on Watercare CoP</i>
<b>Non Residential Demand Typical Daily Consumption Profile / Trend</b>	24 hr operation	<i>E.g. 24 hr operation / 10 hr (9am – 5pm) / Filling on-site storage at certain frequency)</i>

<b>Fire- fighting Classification required by the proposed site</b>	FW3	<i>Refer to New Zealand Standard SNZ PAS 4509:2008</i>
<b>Hydrant Flow Test Results</b>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<i>Attach hydrant flow test layout plan and results showing test date &amp; time; location of hydrants tested and pressure logged; static pressure; flow; residual pressure</i>
<b>Sprinkler System in building?</b>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<i>Sprinkler design should consider Watercare Level of Service: minimum pressure at 200kPa and minimum flow at 25 l/min. The building owner shall conduct periodic review of sprinkler design.</i>
<b>Further Water Supply comments</b>		

*Refer to Water and Wastewater Code of Practice for Land Development and Subdivision Section 5 Wastewater*

<b>Wastewater Development Assessment</b>		
<b>Peak DWF and WWF Residential Design Flows (L/s)</b>	Not Applicable	<i>Show calculations based on Watercare CoP. If relevant for ultimate development scenario include No. of Potential Units/ lots for calculations.</i>
<b>Peak DWF and WWF Non-Residential Design Flows (L/s)</b>	Consent PDWF = 5.26 L/s Consent PWWF = 15.18 L/s	<i>Show calculations based on Watercare CoP.</i>
<b>Non-Residential Discharge Profile / Trend (i.e. Operations)</b>	24 hr operation	<i>E.g. 24 hr operation / 10 hr (9am – 5pm) / Other</i>
<b>New Assets Required for Development</b>	None	<i>If applicable, please provide supporting calculations and indicative design parameters (ie. Pump Station and rising main or storage)</i>
<b>Sewer Capacity Check</b>	119 L/s	<i>Capacity assessment at proposed connection point and impact on network</i>
<b>Further Wastewater comments</b>		

*For internal Watercare use only*

<b>Date Application Received</b>	
<b>Application Ref No.</b>	
<b>Assigned Connections Engineer</b>	
<b>Prior Developer Correspondence with Watercare</b>	
<b>Neighbouring developments to consider in capacity assessment</b>	

# Appendix C – Meeting minutes



**From:** Nicola Black  
**Sent:** Monday, July 27, 2020 11:46 AM  
**To:** IGotelli (Ilze); Margaret Cobeldick; Haitham Alrubayee (WDHB); Paul Stanbridge (WDHB); Matt Capon  
**Cc:** Eric Zhang; Michaela Wilson; Albert Ho; Alistair Osborne; ablomfield@bentley.co.nz  
**Subject:** Masons Clinic - Plan Change Watercare - Meeting Minutes 27/07/20

Hi All

Following our meeting this morning, below are notes and action points going forward;

Item Discussed	Action/Date
<ul style="list-style-type: none"> <li>• Identification of 375mm wastewater pipe through site, needs a CCTV to confirm condition and material of pipe. WDHB to organise and pay for CCTV. Aurecon to assist once Haitham and Paul define process going forward</li> </ul>	WDHB – 31/07
<ul style="list-style-type: none"> <li>• Ilze (Watercare) to confirm any capacity issues with wastewater pipes in area, particular 375mm.</li> </ul>	Watercare – 31/07
<ul style="list-style-type: none"> <li>• Watercare cannot find any as-builts of wastewater pipe – MC thinks this pipe is relatively shallow at 2-2.5m deep</li> </ul>	
<ul style="list-style-type: none"> <li>• Watermain – holistic view of what is happening, new BSP is proposed, Watercare will confirm new location               <ul style="list-style-type: none"> <li>○ Beca are doing Building Services, understand what has been done to date and keep them informed of progress/development.</li> </ul> </li> </ul>	Watercare – 31/07
<ul style="list-style-type: none"> <li>• Where is the secure area in the Masterplan – Aurecon to chase up Klein for plans to show proposed secured areas for Watercare.</li> </ul>	Aurecon/Klein – 29/07

Let me know if you have any questions on the above, or additional points to add.

Kind Regards,

**Nicola Black** BSurv CPEng CMEngNZ  
 Associate – Land Development Consultant, Aurecon  
 M +64 27 2406011  
[Nicola.Black@aurecongroup.com](mailto:Nicola.Black@aurecongroup.com)  
 Level 4, 139 Carlton Gore Road, Newmarket, Auckland New Zealand 1023  
 PO Box 9762, Newmarket, Auckland 1149  
[aurecongroup.com](http://aurecongroup.com)



**DISCLAIMER**

# Appendix D – Upstream flow and capacity check

PROJECT: Mason Clinic Unitary plan change  
 JOB No. 508877  
 DATE: 21/07/2020  
 FOR RESOURCE CONSENT

MASON CLINIC UNITARY PLAN CHANGE  
 EXISTING AND PROPOSED WASTEWATER FLOWS



PDWF Self cleansing design flow  
 PWWF Peak design flow  
 Staff numbers provided by Client

	No.	L/day	Peaking factor		Wastewater flow (L/s)	
			PDWF	PWWF	PDWF	PWWF
Hospital/ Mental Health Facility						
Beds	111	570	1.5	5	1.10	3.66
staff	95	45	2	5	0.10	0.25
<b>Total</b>					<b>1.20</b>	<b>3.91</b>

convert L/d to L/s 86400

**Proposed Wastewater flows based on Watercare COP at stage 2B (2027)**

PDWF Self cleansing design flow  
 PWWF Peak design flow  
 Staff numbers provided by Client

	No.	L/day	Peaking factor		Wastewater flow (L/s)	
			PDWF	PWWF	PDWF	PWWF
Hospital/ Mental Health Facility						
Beds	198	570	1.5	5	1.96	6.53
staff	170	45	2	5	0.18	0.44
<b>Total</b>					<b>2.14</b>	<b>6.97</b>

convert L/d to L/s 86400

PROJECT: Mason Clinic Unitary plan change  
 JOB No. 508877  
 DATE: 21/07/2020  
 FOR RESOURCE CONSENT

MASON CLINIC UNITARY PLAN CHANGE  
 EXISTING AND PROPOSED WASTEWATER FLOWS



**Proposed Wastewater flows based on Watercare COP at stage 3C (2049)**

PDWF Self cleansing design flow  
 PWWF Peak design flow  
 Staff numbers provided by Client

	No.	L/day	Peaking factor		Wastewater flow (L/s)	
			PDWF	PWWF	PDWF	PWWF
Hospital/ Mental Health Facility						
Beds	246	570	1.5	5	2.43	8.11
staff	407	300	2	5	2.83	7.07
<b>Total</b>					<b>5.26</b>	<b>15.18</b>

convert L/d to L/s 86400

	PDWF (L/s)	PWWF (L/s)
<b>Total flow in the 375mm pipe</b>	34.30	81.26

PROJECT: Mason Clinic Unitary plan change  
 JOB No. 508877  
 DATE: 21/07/2020  
 FOR RESOURCE CONSENT

MASON CLINIC UNITARY PLAN CHANGE  
 EXISTING AND PROPOSED WASTEWATER FLOWS



	Area (m2)	No. House: people	Peaking factor		Wastewater flow (L/s)		
			PDWF	PWWF	PDWF	PWWF	
<b>total</b>	<b>796199</b>						
school - pupils	18292	277	2	6.7	0.10	0.32	
School - Staff		18.46666667	2	6.7	0.02	0.06	
Selwyn retirement village - hospital beds	91046	100	1.5	5	0.99	3.30	
Selwyn retirement village - rest home beds		92	3	6.7	0.58	1.28	
Selwyn retirement village - staff		19.2	2	5	0.02	0.05	
park	48500	0					
mixed house suburban	196000	490	1470	3	6.7	9.19	20.52
Mixed housing urban zone	168454	562	1684.54	3	6.7	10.53	23.51
terrace housing and apartments	122000	407	1220	3	6.7	7.63	17.03
Roads	151907						
Unitect performing arts and screen arts - pupils		300	2	6.7	0.10	0.35	
staff		40	2	6.7	0.04	0.05	
<b>Total</b>					<b>29.04</b>	<b>66.08</b>	




**Assumptions**

Housing	3 people per property	taken from COP
	400 average house area	mixed house suburban - Unitary Plan
	300 average house area	Mixed housing urban zone -Unitary Plan
	300 average house area	Terraced housing based on google earth -
School	277 St Francis School roll based on Ero report	
	15 school staff - ratio 1 staff per 15 student	
Selwyn Retirement Village	100 hospital beds	
	92 bed rest home	
	10 hospital staff - ratio 1 staff per 10 people	
Unitec site - Performing Arts	300 pupils enrolled. Obtained from website	
	40 Staff	
Wastewater flow rates and peaking factors Refer to Watercare COP section	180 L/person/day	Residential
	15 L/person/day	students
	45 L/person/day	staff
	570 L/person/day	hospital
convert L/d to L/s	86400	

PROJECT: Mason Clinic Unitary plan change  
JOB No. 508877  
DATE: 21/07/2020  
FOR RESOURCE CONSENT

MASON CLINIC UNITARY PLAN CHANGE  
EXISTING AND PROPOSED WASTEWATER FLOWS





Colebrook-White Formula

All charts in AS2200-2006, have been developed using the formulae below:

$$V = -2(2gDS)^{0.5} \log \left( \frac{k}{3.7D} + \frac{2.5\nu}{D(2gDS)^{0.5}} \right)$$

- k = Colebrook-White roughness coefficient, in metres
- V = velocity, in metres per second
- D = circular cross-section pipe, inside diameter, in metres
- S = slope, in metres per metre
- $\nu$  = kinematic viscosity of water, in square metres per second.

g = Gravity	= 9.81 m/s <sup>2</sup>	
n = kinematic viscosity of water	= 1.010E-06 m <sup>2</sup> /s	
k = Colebrook-White roughness coeff	= 0.150 mm	= 1.500E-04 m
D = Inside diameter	= 375 mm	= 0.375 m
S = Slope, in metres per metre = (Hydraulic Gradient)	= 0.270%	= 0.0027 m/m
V = Velocity	= 1.07 m/s	

Discharge:

$$Q = V \times A \quad A = 0.110 \text{ m}^2 \quad Q = 0.1185 \text{ m}^3/\text{s} \quad = 118.5 \text{ L/s}$$

**Assumptions**

Slope obtained from Watercare GIS maps. This will be confirmed during developed design

# Appendix E – Beca proposed services drawings

**Legend:**

- Plant Space
- In-ground services trench
- Above ground services route
- Pull-Pit
- Services Incomer
- Path of Services rerouting

**SITE SERVICES INCOMERS:**

- 180mm PE POTABLE WATER INCOMER RPZ (3m x 1m)
- 180mm PE FIRE WATER INCOMER RPZ (3m x 1m)
- VECTOR GAS INCOMER METERS (2m x 2m)
- VECTOR HV RING MAIN UNIT (3m x 3m)
- COMMS WAN SUPPLY

EACH SERVICE INCOMER (EXCLUDING COMMS) TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND EACH SERVICE INCOMER

EXISTING GAS SUPPLIES TO MASON TO REMAIN UNTIL RELEVANT EQUIPMENT END OF LIFE WHERE DOMESTIC HEATING SHALL BE REPLACED WITH HOT WATER HEAT PUMP TECHNOLOGY.

**WATER STORAGE**

- FIRE AND POTABLE WATER STORAGE TANKS, ALLOW FOR 50,000 LITRES EACH (5m DIA EACH)
- POTABLE WATER PUMP STATION (20m<sup>2</sup>)
- FIRE WATER DIESEL PUMP AND FUEL STORAGE (30m<sup>2</sup>)

**SERVICES TRENCH**

SECTION CONTAINS:

- 200mm STEEL CHILLED WATER FLOW AND RETURN
- 150mm STEEL HEATING HOT WATER FLOW AND RETURN
- 180mm PE POTABLE WATER
- 180mm PE FIRE WATER
- 3 x 100mm COMMS CONDUITS
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE
- LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

**SITE SERVICES RE-ROUTING**

THE FOLLOWING SERVICES DON'T SERVE THE MASON SITE BUT NEED TO BE RUN THROUGH OR AROUND THE MASON SITE:

- 1 x 100mm and 2 x 50mm GAS SUPPLIES TO SERVE TAYLOR'S AND UNITEC
- 2 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLES TO SERVE TAYLOR'S AND UNITEC

**NOTE 1**

THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED BUILDING SERVICES WHICH ARE PROPOSED TO BE RETAINED UNTIL THE END OF THEIR ECONOMIC LIFE. AT SUCH TIME, THE BUILDINGS SHALL BE SUPPLIED WITH SERVICES FROM THE NEW RING MAIN DISTRIBUTION TO SUIT THE END STATE INFRASTRUCTURE ARRANGEMENT.

**NOTE 2:**

EACH NEW BUILDING TO INCLUDE THE FOLLOWING:

- 2 x CHILLED WATER PUMPS (NOMINAL 12l/s / 150kPa EACH) AND 100mm COPPER CHILLED WATER DISTRIBUTION THROUGHOUT
- 2 x HEATING HOT WATER PUMPS (NOMINAL 6l/s / 150kPa EACH) AND 80mm COPPER DISTRIBUTION THROUGHOUT
- ESSENTIAL AND NON-ESSENTIAL SWITCHBOARDS WITH 2 x 4C 300mm<sup>2</sup> LV SUPPLIES FED FROM RELEVANT ENERGY CENTRE. LIGHTING AND POWER DISTRIBUTION THROUGHOUT
- 2 x 30kW DOMESTIC HOT WATER HEAT PUMPS AND COPPER DOMESTIC HOT WATER RETICULATION THROUGHOUT
- 100mm FIRE WATER SUPPLY (INDIVIDUAL BRANCH TAKEOFFS TO INCLUDE THREE SLUICE VALVES TO ALLOW RING MAIN OPERATION)
- 65mm POTABLE WATER (INDIVIDUAL BRANCH TAKEOFFS TO INCLUDE THREE SLUICE VALVES TO ALLOW RING MAIN OPERATION)

**ABOVE GROUND SERVICES ROUTE**

SECTION CONTAINS:

- 200mm STEEL CHILLED WATER FLOW AND RETURN
- 150mm STEEL HEATING HOT WATER FLOW AND RETURN
- 180mm PE POTABLE WATER
- 180mm PE FIRE WATER
- 3 x 100mm COMMS CONDUITS
- LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS VIA CABLE LADDERS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE (UNDERGROUND)

**NORTH ENERGY CENTRE (550m<sup>2</sup>)**

INTERNAL ROOMS INCLUDE:

- 6 x 30l/s / 300kPa PUMPS 2 x BUFFER TANKS (100m<sup>2</sup>)
- 2 x 1MVA TRANSFORMERS, 2 x 1MVA GENERATORS, HV RMU, MSB (200m<sup>2</sup>)

EXTERNAL ROOMS INCLUDE:

- 10,000L DIESEL FUEL STORAGE (50m<sup>2</sup>)
- 3 x 800kW AIR COOLED HEAT PUMP CHILLERS (200m<sup>2</sup>)

**SERVICES TRENCH**

SECTION CONTAINS:

- 180mm PE POTABLE WATER
- 180mm PE FIRE WATER
- 3 x 100mm COMMS CONDUITS
- 4 x 100mm CONDUITS FOR FUTURE HV AND LV RING MAIN

**EXISTING SERVICES SUPPLIES**

- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO UNITEC
- 50mm GAS SUPPLY TO UNITEC

**SITE SERVICES INCOMERS:**

- 180mm PE POTABLE WATER INCOMER RPZ (3m x 1m)
- 180mm PE FIRE WATER INCOMER RPZ (3m x 1m)
- COMMS WAN SUPPLY


EACH SERVICE INCOMER (EXCLUDING COMMS) TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND EACH SERVICE INCOMER

**EXISTING SERVICES SUPPLIES**

- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO TAYLOR'S
- 100mm GAS SUPPLY TO TAYLOR'S

EXISTING BOILER PLANT AND GAS SUPPLY TO REMAIN. HEATING SOURCES TO BE TRANSFERRED TO ENERGY CENTRE DURING TRANCHE 2 AND 3

EXISTING ELECTRICAL SUBSTATION TO REMAIN. LOADS TO BE SHIFTED TO NEW ENERGY CENTRE DURING TRANCHE 2 AND 3



B	PBC 2 ISSUE	NF	SS	SS	12/06/19
A	DRAFT - FOR INFORMATION	NF	SS	SS	31/05/19
No.	Revision	By	Chk	Appd	Date

Drawing Originator:

Original Scale (A1)	Design	NF
Reduced Scale (A3)	Drawn	NF
	Disg Verifier	SS
	Dwg Check	SS
	Date	

\* Refer to Revision 1 for Original Signature

Client:

Project: MASON CLINIC MASTERPLAN BUSINESS CASE 2019

Title: OVERALL SERVICES REQUIREMENTS TRANCHE 1

Discipline:	COMBINED SERVICES
Drawing No.:	CSK-100
Rev:	B



**Legend:**

- Plant Space
- In-ground services trench
- Above ground services route
- Pull-Pit
- Services Incomer
- Path of Services rerouting

**NOTE 1**

THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED BUILDING SERVICES WHICH ARE PROPOSED TO BE RETAINED UNTIL THE END OF THEIR ECONOMIC LIFE. AT SUCH TIME, THE BUILDINGS SHALL BE SUPPLIED WITH SERVICES FROM THE NEW RING MAIN DISTRIBUTION TO SUIT THE END STATE INFRASTRUCTURE ARRANGEMENT.

**NOTE 2:**

EACH NEW BUILDING TO INCLUDE THE FOLLOWING:

- 2 x CHILLED WATER PUMPS (NOMINAL 12l/s / 150kPa EACH) AND 100mm COPPER CHILLED WATER DISTRIBUTION THROUGHOUT
- 2 x HEATING HOT WATER PUMPS (NOMINAL 6l/s / 150kPa EACH) AND 80mm COPPER DISTRIBUTION THROUGHOUT
- ESSENTIAL AND NON-ESSENTIAL SWITCHBOARDS WITH 2 x 4C 300mm<sup>2</sup> LV SUPPLIES FED FROM RELEVANT ENERGY CENTRE. LIGHTING AND POWER DISTRIBUTION THROUGHOUT
- 2 x 30kW DOMESTIC HOT WATER HEAT PUMPS AND COPPER DOMESTIC HOT WATER RETICULATION THROUGHOUT
- 100mm FIRE WATER SUPPLY (INDIVIDUAL BRANCH TAKEOFFS TO INCLUDE THREE SLUICE VALVES TO ALLOW RING MAIN OPERATION)
- 65mm POTABLE WATER (INDIVIDUAL BRANCH TAKEOFFS TO INCLUDE THREE SLUICE VALVES TO ALLOW RING MAIN OPERATION)

**SERVICES TRENCH**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

**ABOVE GROUND SERVICES ROUTE**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS VIA CABLE LADDERS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

**SITE SERVICES INCOMERS:**

- 180mm PE POTABLE WATER INCOMER RPZ (3m x 1m)
- 180mm PE FIRE WATER INCOMER RPZ (3m x 1m)
- VECTOR GAS INCOMER METERS (2m x 2m)
- VECTOR HV RING MAIN UNIT (3m x 3m)
- COMMS WAN SUPPLY

EACH SERVICE INCOMER (EXCLUDING COMMS) TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND EACH SERVICE INCOMER

EXISTING GAS SUPPLIES TO MASON TO REMAIN UNTIL RELEVANT EQUIPMENT END OF LIFE WHERE DOMESTIC HEATING SHALL BE REPLACED WITH HOT WATER HEAT PUMP TECHNOLOGY.

**WATER STORAGE**

- FIRE AND POTABLE WATER STORAGE TANKS, ALLOW FOR 50,000 LITRES EACH (5m DIA EACH)
- POTABLE WATER PUMP STATION (20m<sup>2</sup>)
- FIRE WATER DIESEL PUMP AND FUEL STORAGE (30m<sup>2</sup>)

**SERVICES TRENCH**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

**ABOVE GROUND SERVICES ROUTE**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS VIA CABLE LADDERS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)  
 - 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE (UNDERGROUND)

**NORTH ENERGY CENTRE (550m<sup>2</sup>)**

- INTERNAL ROOMS INCLUDE:**
- 6 x 30l/s / 300KPa PUMPS 2 x BUFFER TANKS (100m<sup>2</sup>)
  - 2 x 1MVA TRANSFORMERS, 2 x 1MVA GENERATORS, HV RMU, MSB (200m<sup>2</sup>)
- EXTERNAL ROOMS INCLUDE:**
- 10,000L DIESEL FUEL STORAGE (50m<sup>2</sup>)
  - 3 x 800kW AIR COOLED HEAT PUMP CHILLERS (200m<sup>2</sup>)

**SERVICES TRENCH**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

**EXISTING SERVICES SUPPLIES**

- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO UNITEC
- 50mm GAS SUPPLY TO UNITEC

**SITE SERVICES INCOMERS:**

- 180mm PE POTABLE WATER INCOMER RPZ (3m x 1m)
- 180mm PE FIRE WATER INCOMER RPZ (3m x 1m)
- COMMS WAN SUPPLY

EACH SERVICE INCOMER (EXCLUDING COMMS) TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND EACH SERVICE INCOMER

**EXISTING SERVICES SUPPLIES**

- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO TAYLOR'S
- 100mm GAS SUPPLY TO TAYLOR'S

**SOUTH ENERGY CENTRE (550m<sup>2</sup>)**

- INTERNAL ROOMS INCLUDE:**
- 6 x 30l/s / 300KPa PUMPS 2 x BUFFER TANKS (100m<sup>2</sup>)
  - 2 x 1MVA TRANSFORMERS, 2 x 1MVA GENERATORS, HV RMU, MSB (200m<sup>2</sup>)
- EXTERNAL ROOMS INCLUDE:**
- 10,000L DIESEL FUEL STORAGE (50m<sup>2</sup>)
  - 3 x 800kW AIR COOLED HEAT PUMP CHILLERS (200m<sup>2</sup>)

**SERVICES TRENCH**

SECTION CONTAINS:  
 - 200mm STEEL CHILLED WATER FLOW AND RETURN  
 - 150mm STEEL HEATING HOT WATER FLOW AND RETURN  
 - 180mm PE POTABLE WATER  
 - 180mm PE FIRE WATER  
 - 3 x 100mm COMMS CONDUITS  
 - 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY CABLE  
 - LV DISTRIBUTION FROM ENERGY CENTRE TO BUILDINGS (2 x 4C 300mm<sup>2</sup> LV SUPPLIES PER BUILDING)

TYPICAL PULL PIT TO ACCESS AND INSTALL SERVICES

B	PBC 2 ISSUE	NF	SS	SS	12/06/19
A	DRAFT - FOR INFORMATION	NF	SS	SS	31/05/19
No.	Revision	By	Chk	Appd	Date



Original Scale (A1)	Design	NF
Reduced Scale (A3)	Drawn	NF
	Disg Verifier	SS
	Dwg Check	SS



Client: **Waitemata District Health Board**  
 Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Title: <b>OVERALL SERVICES REQUIREMENTS END STATE</b>	Discipline: <b>COMBINED SERVICES</b>
Drawing No: <b>CSK-101</b>	Rev: <b>B</b>



**LEGEND:**

- IN-GROUND (TRENCHED) CHILLED WATER
- ABOVE GROUND CHILLED WATER
- ✕ ISOLATION VALVE
- ▲ SUPPLY CENTRE
- LOAD CENTRE
- ⊕ PUMP

**NOTE 1 -** THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED COOLING WHICH IS PROPOSED TO BE RETAINED UNTIL THE END OF ITS ECONOMIC LIFE. AT SUCH TIME, THE BUILDING SHALL BE SUPPLIED FROM THE CHILLED WATER RING MAIN TO MATCH THE END STATE CHILLED WATER ARRANGEMENT.

**NOTE 2 -** CHILLED WATER RING MAIN TO BE Ø200 STEEL THROUGHOUT

**LOAD CENTRE**

AREA: 5000 sqm  
 LOAD: 350 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 14 l/s  
 SECONDARY PUMPS: 2 @ 14l/s /150kPa (Duty/Standby)

**LOAD CENTRE**

AREA: 3000 sqm  
 LOAD: 210 kW  
 PIPE SIZE: Ø80mm  
 FLOW: 8 l/s  
 SECONDARY PUMPS: 2 @ 8l/s /150kPa (Duty/Standby)

**NORTH ENERGY CENTRE**


CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**

AREA: 4200 sqm  
 LOAD: 294 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 12 l/s  
 SECONDARY PUMPS: 2 @ 12l/s / 150kPa

TANEKAHA BUILDING SERVED FROM STANDALONE PLANT AT COMPLETION OF TRANCHE 1. TRANCHE 2 AND 3 CHILLER LOADS TO ALLOW FOR FUTURE CONNECTION OF THIS BUILDING

VALVED CHW PIPEWORK FOR FUTURE EXTENSION UNDER TRANCHE 2 WORKS



No.	Revision	By	Chk	Appd	Date
A	PBC 2 ISSUE	NF	SS	SS	12/06/19

Drawing Originator:

Original Scale (A1)	Design	NF
Reduced Scale (A3)	Drawn	NF
	Desig Verifier	SS
	Dwg Check	SS

\* Refer to Revision 1 for Original Signature

Client:

Project: MASON CLINIC MASTERPLAN BUSINESS CASE 2019

Title: CHILLED WATER LAYOUT TRANCHE 1

Discipline	MECHANICAL
Drawing No.	MSK-100
Rev.	A



**LEGEND:**

- IN-GROUND (TRENCHED) CHILLED WATER
- ABOVE GROUND CHILLED WATER
- ⚡ ISOLATION VALVE
- ▲ SUPPLY CENTRE
- LOAD CENTRE
- ⊕ PUMP

**NOTE 1 -** THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED COOLING WHICH IS PROPOSED TO BE RETAINED UNTIL THE END OF ITS ECONOMIC LIFE. AT SUCH TIME, THE BUILDING SHALL BE SUPPLIED FROM THE CHILLED WATER RING MAIN TO MATCH THE END STATE CHILLED WATER ARRANGEMENT.

**NOTE 2 -** CHILLED WATER RING MAIN TO BE Ø200 STEEL THROUGHOUT

NORMALLY CLOSED CHW ISOLATING VALVES AT DEMARCATION BETWEEN NORTH AND SOUTH ENERGY CENTRE SUPPLIES. VALVES MAY BE OPENED IN THE EVENT THAT EITHER ENERGY CENTRE CANNOT PRODUCE CHW

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 294 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 12 l/s  
 SECONDARY PUMPS: 2 @ 12l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 294 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 12 l/s  
 SECONDARY PUMPS: 2 @ 12l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 763 sqm  
 LOAD: 53 kW  
 PIPE SIZE: Ø50mm  
 FLOW: 2 l/s  
 SECONDARY PUMPS: 2 @ 2l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 3800 sqm  
 LOAD: 266 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 11 l/s  
 SECONDARY PUMPS: 2 @ 11l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 376 sqm  
 LOAD: 26 kW  
 PIPE SIZE: Ø40mm  
 FLOW: 1 l/s  
 SECONDARY PUMPS: 2 @ 1l/s /150kPa (Duty/Standby)

**SOUTH ENERGY CENTRE**  
 CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**  
 AREA: 1000 sqm  
 LOAD: 74 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 3 l/s  
 SECONDARY PUMPS: 2 @ 3l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1800 sqm  
 LOAD: 126 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1530 sqm  
 LOAD: 107 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 4 l/s  
 SECONDARY PUMPS: 2 @ 4l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 294 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 12 l/s  
 SECONDARY PUMPS: 2 @ 12l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 5000 sqm  
 LOAD: 350 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 14 l/s  
 SECONDARY PUMPS: 2 @ 14l/s /150kPa (Duty/Standby)


**LOAD CENTRE**  
 AREA: 3000 sqm  
 LOAD: 210 kW  
 PIPE SIZE: Ø80mm  
 FLOW: 8 l/s  
 SECONDARY PUMPS: 2 @ 8l/s /150kPa (Duty/Standby)

**NORTH ENERGY CENTRE**  
 CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 294 kW  
 PIPE SIZE: Ø100mm  
 FLOW: 12 l/s  
 SECONDARY PUMPS: 2 @ 12l/s /150kPa

**LOAD CENTRE**  
 AREA: 1850 sqm  
 LOAD: 130 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1800 sqm  
 LOAD: 126 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)



Original Scale (A1)	Design	NF			
Reduced Scale (A3)	Drawn	NF			
	Disg Verifier	SS			
	Dwg Check	SS			
					Date

Drawing Originator: **Beca**

Client: **Waitemata District Health Board**

Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Discipline: **MECHANICAL**

Drawing No: **MSK-101**

Rev: **A**

Original Scale (A1)

Design: NF

Drawn: NF

Disg Verifier: SS

Dwg Check: SS

Date:

Refer to Revision 1 for Original Signature

DO NOT SCALE

IF IN DOUBT ASK.

www.beca.com

www.beca.com



**LEGEND:**

- IN-GROUND (TRENCHED) HOT WATER
- ABOVE GROUND HOT WATER
- ✂ ISOLATION VALVE
- ▲ SUPPLY CENTRE
- LOAD CENTRE
- ⊕ PUMP

**NOTE 1** - THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED HEATING WHICH IS PROPOSED TO BE RETAINED UNTIL THE END OF ITS ECONOMIC LIFE. AT SUCH TIME, THE BUILDING SHALL BE SUPPLIED FROM THE HEATING HOT WATER RING MAIN TO MATCH THE END STATE HEATING WATER ARRANGEMENT.

**NOTE 2** - HEATING WATER RING MAIN TO BE Ø150 STEEL THROUGHOUT

**LOAD CENTRE**

AREA: 5000 sqm  
 LOAD: 260 kW  
 PIPE SIZE: Ø80mm  
 FLOW: 6 l/s  
 SECONDARY PUMPS: 2 @ 6l/s /150kPa (Duty/Standby)

**LOAD CENTRE**

AREA: 3000 sqm  
 LOAD: 156 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 4 l/s  
 SECONDARY PUMPS: 2 @ 4l/s /150kPa (Duty/Standby)

**NORTH ENERGY CENTRE**

CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**


AREA: 4200 sqm  
 LOAD: 218 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s / 150kPa

TANEKAHA BUILDING SERVED FROM STANDALONE PLANT AT COMPLETION OF TRANCHE 1. TRANCHE 2 HEATING LOADS TO ALLOW FOR FUTURE CONNECTION OF THIS BUILDING

VALVED HHW PIPEWORK FOR FUTURE EXTENSION UNDER TRANCHE 2 WORKS

NOTE 2

NOTE 1



No.	Revision	By	Chk	Appd	Date
A	PBC 2 ISSUE	NF	SS	SS	12/06/19

Drawing Originator: **Beca**

Original Scale (A1): NF

Reduced Scale (A3): NF

Design: NF

Drawn: NF

Disg Verifier: SS

Dwg Check: SS

\* Refer to Revision 1 for Original Signature

Client: **Waitemata District Health Board**

Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Title: **HOT WATER LAYOUT TRANCHE 1**

Discipline: **MECHANICAL**

Drawing No: **MSK-102**

Rev: **A**



**LEGEND:**

- IN-GROUND (TRENCHED) HOT WATER
- ABOVE GROUND HOT WATER
- ⊘ ISOLATION VALVE
- ▲ SUPPLY CENTRE
- LOAD CENTRE
- ⊕ PUMP

**NOTE 1 -** THESE IDENTIFIED BUILDINGS HAVE EXISTING SELF CONTAINED HEATING WHICH IS PROPOSED TO BE RETAINED UNTIL THE END OF ITS ECONOMIC LIFE. AT SUCH TIME, THE BUILDING SHALL BE SUPPLIED FROM THE HEATING HOT WATER RING MAIN TO MATCH THE END STATE HEATING WATER ARRANGEMENT.

**NOTE 2 -** HEATING WATER RING MAIN TO BE Ø150 STEEL THROUGHOUT

NORMALLY CLOSED HHW ISOLATING VALVES AT DEMARCATION BETWEEN NORTH AND SOUTH ENERGY CENTRE SUPPLIES. VALVES MAY BE OPENED IN THE EVENT THAT EITHER ENERGY CENTRE CANNOT PRODUCE HHW

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 218 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 218 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 763 sqm  
 LOAD: 40 kW  
 PIPE SIZE: Ø40mm  
 FLOW: 1 l/s  
 SECONDARY PUMPS: 2 @ 1l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 3800 sqm  
 LOAD: 198 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 376 sqm  
 LOAD: 20 kW  
 PIPE SIZE:  
 FLOW: <1 l/s  
 SECONDARY PUMPS:

**SOUTH ENERGY CENTRE**  
 CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**  
 AREA: 1050 sqm  
 LOAD: 55 kW  
 PIPE SIZE: Ø40mm  
 FLOW: 1 l/s  
 SECONDARY PUMPS: 2 @ 1l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1800 sqm  
 LOAD: 94 kW  
 PIPE SIZE: Ø50mm  
 FLOW: 2 l/s  
 SECONDARY PUMPS: 2 @ 2l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1530 sqm  
 LOAD: 80 kW  
 PIPE SIZE: Ø50mm  
 FLOW: 2 l/s  
 SECONDARY PUMPS: 2 @ 2l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 218 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 5000 sqm  
 LOAD: 260 kW  
 PIPE SIZE: Ø80mm  
 FLOW: 6 l/s  
 SECONDARY PUMPS: 2 @ 6l/s /150kPa (Duty/Standby)


**LOAD CENTRE**  
 AREA: 3000 sqm  
 LOAD: 156 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 4 l/s  
 SECONDARY PUMPS: 2 @ 4l/s /150kPa (Duty/Standby)

**NORTH ENERGY CENTRE**  
 CHILLER 1 (HEAT PUMP) = 800 kW  
 CHILLER 2 (HEAT PUMP) = 800 kW  
 CHILLER 3 (HEAT PUMP) = 800 kW  
 TOTAL CAPACITY = 1600 kW (N+1)  
 PRIMARY PUMPS = 3 @ 30l/s / 300kPa (N+1)

**LOAD CENTRE**  
 AREA: 4200 sqm  
 LOAD: 218 kW  
 PIPE SIZE: Ø65mm  
 FLOW: 5 l/s  
 SECONDARY PUMPS: 2 @ 5l/s / 150kPa

**LOAD CENTRE**  
 AREA: 1850 sqm  
 LOAD: 96kW  
 PIPE SIZE: Ø50mm  
 FLOW: 2 l/s  
 SECONDARY PUMPS: 2 @ 2l/s /150kPa (Duty/Standby)

**LOAD CENTRE**  
 AREA: 1800 sqm  
 LOAD: 94 kW  
 PIPE SIZE: Ø50mm  
 FLOW: 2 l/s  
 SECONDARY PUMPS: 2 @ 2l/s /150kPa (Duty/Standby)



Original Scale (A1)	Design	NF			
Reduced Scale (A3)	Drawn	NF			
	Disg Verifier	SS			
	Dwg Check	SS			
					Date

Drawing Originator: **Beca**

Client: **Waitemata District Health Board**

Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Discipline: **MECHANICAL**

Title: **HOT WATER LAYOUT END STATE**

Revision: **A**


Original Scale (A1)	Design	NF			
Reduced Scale (A3)	Drawn	NF			
	Disg Verifier	SS			
	Dwg Check	SS			
					Date



**LEGEND:**

- NEW IN-GROUND HV ELECTRICAL CABLE
- NEW ABOVE LV ELECTRICAL CABLE
- RE-ROUTED HV CABLE
- EXISTING LV SUBMAIN
- EXISTING HV CABLE
- MAIN SWITCHBOARD
- DISTRIBUTION BOARD
- HV RING MAIN UNIT

**NOTE 1 -** IN ORDER TO SUPPLY THE NEW TANEKAHA BUILDING IT IS PLANNED TO INSTALL A NEW MAIN SWITCH BOARD TO SUPPLY THE EXISTING MAIN SWITCH BOARD AND THE NEW TANEKAHA BUILDING. IT IS CONSIDERED FEASIBLE TO RE-USE/RELOCATE THE GENERATOR/S AND TRANSFORMER/S TO THE NORTH ENERGY CENTRE AS PART OF EITHER THE TRANCHE 1 OR 2 NORTH ENERGY CENTRE WORKS



UPGRADE EXISTING RMU

**LOAD CENTRE**  
AREA: 4700 sqm  
LOAD: 190 kVA

**LOAD CENTRE**  
AREA: 2800 sqm  
LOAD: 110 kVA

**Front of House & Shared Activity Centre**  
GFA 3095m<sup>2</sup>

**Energy Centre**  
GFA 504m<sup>2</sup>

**NORTH ENERGY CENTRE**

TRANSFORMER 1 = 1000 kVA  
TRANSFORMER 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**

GENERATOR 1 = 1000 kVA  
GENERATOR 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**

FUEL TANK = 10,000 Litre

MAIN SWITCHBOARD = 2000 AMP, FORM 4b, 50 kA FAULT  
11,000 VOLT SWITCHBOARD OR RING MAIN UNIT

TRANSFORMERS AND GENERATORS TO BE RELOCATED TO NORTH ENERGY CENTRE FROM EXISTING SUBSTATION DURING TRANCHE 2/3 WORKS

**LOAD CENTRE**  
AREA: 4200 sqm  
LOAD: 170 kVA

**EXISTING HV CABLE RE-ROUTED**  
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO UNITEC

TANEKAHA BUILDING SERVED FROM EXISTING SUBSTATION AT END OF TRANCHE 1. BUILDING TO BE CHANGED OVER TO NORTH ENERGY CENTRE DURING TRANCHE 2/3 WORKS

**EXISTING HV CABLE RE-ROUTED**  
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO TAYLOR'S

**EXISTING SUBSTATION**

TRANSFORMER 1 = 1000 kVA  
TRANSFORMER 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**

GENERATOR 1 = 1000 kVA  
GENERATOR 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**

FUEL TANK = 10,000 Litre

MAIN SWITCHBOARD = 2000 AMP, FORM 4b, 50 kA FAULT  
11,000 VOLT RING MAIN UNIT

GENERATORS AND TRANSFORMERS TO BE MOVED OVER TO NORTH ENERGY CENTRE DURING TRANCHE 2/3 WORKS

A		PBC 2 ISSUE		RD	SS	SS	12/06/19
No.	Revision	By	Chk	Appd	Date		

Drawing Originator:

Original Scale (A1)	Design	RD
Reduced Scale (A3)	Drawn	RD
	Disg Verifier	SS
	Dwg Check	SS
	* Refer to Revision 1 for Original Signature	

Client:

Project: MASON CLINIC MASTERPLAN BUSINESS CASE 2019

Title: ELECTRICAL LAYOUT TRANCHE 1

Discipline:	ELECTRICAL
Drawing No.:	ESK-100
Rev.:	A



**LEGEND:**

- IN-GROUND (TRENCHED) ELECTRICAL CABLE
- ABOVE GROUND ELECTRICAL CABLE
- PATH OF RE-ROUTED HV CABLE
- ■ ■ ■ ■ MAIN SWITCHBOARD
- ■ ■ ■ ■ DISTRIBUTION BOARD
- ■ ■ ■ ■ HV RING MAIN UNIT

**NOTE 1 - THE TANEKAHA BUILDING ELECTRICAL LOAD SHALL BE TRANSFERRED TO THE NORTH ENERGY CENTRE DURING TRANCHE 2/3 WORKS**

**LOAD CENTRE**  
AREA: 763 sqm  
LOAD: 30 kVA

**LOAD CENTRE**  
AREA: 3800 sqm  
LOAD: 152 kVA

**LOAD CENTRE**  
AREA: 376 sqm  
LOAD: 15 kVA

**SOUTH ENERGY CENTRE**  
TRANSFORMER 1 = 1000 kVA  
TRANSFORMER 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**  
  
GENERATOR 1 = 1000 kVA  
GENERATOR 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**  
  
FUEL TANK = 10,000 Litre  
  
MAIN SWITCHBOARD = 2000 AMP, FORM 4b, 50 kA FAULT  
11,000 VOLT SWITCHBOARD OR RING MAIN UNIT

**LOAD CENTRE**  
AREA: 1050 sqm  
LOAD: 42 kVA

**LOAD CENTRE**  
AREA: 4200 sqm  
LOAD: 170 kVA

**LOAD CENTRE**  
AREA: 4200 sqm  
LOAD: 170 kVA

**LOAD CENTRE**  
AREA: 4200 sqm  
LOAD: 170 kVA

**LOAD CENTRE**  
AREA: 1800 sqm  
LOAD: 72 kVA

**LOAD CENTRE**  
AREA: 1530 sqm  
LOAD: 61 kVA

SERVED FROM SOUTH ENERGY CENTRE

SERVED FROM NORTH ENERGY CENTRE

**LOAD CENTRE**  
AREA: 5000 sqm  
LOAD: 200 kVA

**LOAD CENTRE**  
AREA: 3000 sqm  
LOAD: 120 kVA

**NORTH ENERGY CENTRE**  
TRANSFORMER 1 = 1000 kVA  
TRANSFORMER 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**  
  
GENERATOR 1 = 1000 kVA  
GENERATOR 2 = 1000 kVA  
**TOTAL CAPACITY = 2000 kVA (N+1)**  
  
FUEL TANK = 10,000 Litre  
  
MAIN SWITCHBOARD = 2000 AMP, FORM 4b, 50 kA FAULT  
11,000 VOLT SWITCHBOARD OR RING MAIN UNIT

**LOAD CENTRE**  
AREA: 4200 sqm  
LOAD: 170 kVA

**EXISTING SERVICES SUPPLIES**  
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO UNITEC

**LOAD CENTRE**  
AREA: 1850 sqm  
LOAD: 74 kVA

**LOAD CENTRE**  
AREA: 1800 sqm  
LOAD: 72 kVA

**EXISTING SERVICES SUPPLIES**  
- 1 x 3C 185mm<sup>2</sup> Cu HV SUPPLY TO TAYLOR'S

A		PBC 2 ISSUE		RD	SS	SS	12/06/19
No.	Revision	By	Chk	Appd	Date		



Original Scale (A1)	Design	RD
Reduced Scale (A3)	Drawn	RD
	Disg Verifier	SS
	Dwg Check	SS
	Date	

\* Refer to Revision 1 for Original Signature



Client: **Waitemata District Health Board**  
Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Title: **ELECTRICAL LAYOUT END STATE**

Discipline:	ELECTRICAL
Drawing No.:	ESK-101
Rev.:	A



**LEGEND:**

- - - EXISTING POTABLE WATER
- NEW POTABLE WATER
- - - EXISTING FIRE WATER
- NEW FIRE WATER
- NEW ISOLATION VALVE
- SUPPLY CENTRE
- LOAD CENTRE

**NOTES:**

1. Pipes sizes shown are nominal internal diameter bore
2. Unless noted otherwise all new potable and fire water lines are PE180
3. Every Tee junction will have 3 sluice/gate valves either side of main and the branch.
5. A series of auto valves will be required to segregate tank makeup and ring main distribution in pumping mode and normal mode.

**MAINS WATER INCOMER 1:**

- UPGRADE EXISTING Ø150 TO Ø180 METERED PE POTABLE WATER INCOMER C/W RPZ (3m x 1m)
- NEW Ø180 PE FIRE WATER INCOMER C/W RPZ (3m x 1m)

EACH INCOMER TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND EACH INCOMER

**WATER STORAGE**

- FIRE AND POTABLE WATER STORAGE TANKS, ALLOW FOR 50,000 LITRES EACH (Ø5m EACH)
- POTABLE WATER PUMP STATION (20m<sup>2</sup>)
- FIRE WATER DIESEL PUMP AND FUEL STORAGE (30m<sup>2</sup>)

NEW VALVED PIPEWORK FOR FUTURE EXTENSION UNDER TRANCHE 2 WORKS

NEW VALVED PIPEWORK FOR FUTURE EXTENSION UNDER TRANCHE 2 WORKS


TYPICAL POTABLE AND FIRE WATER SUPPLY TO EACH BUILDING

VALVED POTABLE AND FIRE WATER PIPEWORK FOR FUTURE EXTENSION UNDER TRANCHE 2 AND 3 WORKS

EXISTING POTABLE AND FIRE WATER DISTRIBUTION NETWORK REMAINS UNCHANGED TO EXISTING BUILDINGS UNDER TRANCHE 1 WORKS.

WATER SUPPLIES TO EXISTING BUILDINGS TO BE CHANGED OVER TO THE NEW POTABLE AND FIRE WATER RING MAINS INSTALLED UNDER TRANCHE 2 AND 3 WORKS

TO UNITEC SITE



A		PBC 2 ISSUE		NF	SS	SS	12/06/19
No.	Revision	By	Chk	Appd	Date		

Drawing Originator: **Beca**

Original Scale: (A1)  
Reduced Scale: (A3)

Design:	NF
Drawn:	NF
Desig Verifier:	SS
Dwg Check:	SS

\* Refer to Revision 1 for Original Signature

Client: **Waitemata District Health Board**

Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Title: **POTABLE AND FIRE WATER LAYOUT TRANCHE 1**

Discipline: **HYDRAULIC**

Drawing No: **HYD-100**

Rev: **A**



**LEGEND:**

- EXISTING POTABLE WATER
- NEW POTABLE WATER
- EXISTING FIRE WATER
- NEW FIRE WATER
- NEW ISOLATION VALVE
- SUPPLY CENTRE
- LOAD CENTRE

**NOTES:**

1. Pipes sizes shown are nominal internal diameter bore
2. Unless noted otherwise all new potable and fire water lines are PE180
3. Every Tee junction will have 3 sluice/gate valves either side of main and the branch.
5. A series of auto valves will be required to segregate tank makeup and ring main distribution in pumping mode and normal mode.

**WATER STORAGE**

- FIRE AND POTABLE WATER STORAGE TANKS, ALLOW FOR 50,000 LITRES EACH (Ø5m EACH)
- POTABLE WATER PUMP STATION (20m<sup>2</sup>)
- FIRE WATER DIESEL PUMP AND FUEL STORAGE (30m<sup>2</sup>)

**MAINS WATER INCOMER 1:**

- Ø180 METERED PE POTABLE WATER INCOMER RPZ (3m x 1m)
- Ø180 PE FIRE WATER INCOMER RPZ (3m x 1m)

TYPICAL POTABLE AND FIRE WATER SUPPLY TO EACH BUILDING


**MAINS WATER INCOMER 2:**

- UPGRADE TO Ø180mm METERED PE POTABLE WATER INCOMER RPZ (3m x 1m)
- NEW Ø180mm PE FIRE WATER INCOMER RPZ (3m x 1m)

SERVICE INCOMER TO BE PROVIDED WITH LOCKABLE CHAIN LINK FENCE SURROUND, OR SIMILAR. PROVIDE CIRCULATION SPACE WITHIN AND AROUND SERVICE INCOMER

EXISTING POTABLE AND FIRE WATER DISTRIBUTION NETWORK REMAINS UNCHANGED TO EXISTING BUILDINGS UNDER TRANCHE 1 WORKS.

WATER SUPPLIES TO EXISTING BUILDINGS TO BE CHANGED OVER TO THE NEW POTABLE AND FIRE WATER RING MAINS INSTALLED UNDER TRANCHE 2 AND 3 WORKS



A		PBC 2 ISSUE		By	NF	SS	SS	12/06/19
No.	Revision	By	Chk	Appd	Date			



Original Scale (A1)	Design	NF
Reduced Scale (A3)	Drawn	NF
	Disg Verifier	SS
	Dwg Check	SS
	Date	

\* Refer to Revision 1 for Original Signature



Client: **Waitemata District Health Board**

Project: **MASON CLINIC MASTERPLAN BUSINESS CASE 2019**

Title: **POTABLE AND FIRE WATER LAYOUT END STATE**

Discipline	HYDRAULIC
Drawing No.	HYD-101
Rev.	A



# Appendix F – Hydrant testing result



**FIRE HYDRANT / SITE WATER MAIN FLOW TEST**

Date: OCT 2017. Site: CARRINGTON HOSPITAL MAIN SITE.  
Address: CARRINGTON ROAD -AUCKLAND. Building Number: SITE COMBINE MAIN.

Client: WAITEMATA .D.H.B

Site water main (ringmain) (signal ended main): RINGMAIN-FEEDED BY -1X150mm SINGLE COUNCIL SUPPLY FROM GREAT NORTH ROAD (MOTORWAY SIDE OF SITE).

Size of Towns main : HOSPITAL SUPPLY 150mm ...AND 1X EMERGENCY 100mm SINGLE FEED FROM UNTEC (KEEPEE CLOSED).

Town's main boosted pump/tank or other : N/A

Tank capacity : N/A

Back Flow: 1X 150mm FEEDED FROM GREAT NORTH ROAD.

Size of Back Flow: 150mm.

Other connections to site fire water mains : Council Supply Lake Supply Tank Supply Bore Supply

Comments: SITE WATER SUPPLY DRAWINGS DATED MARCH1971 AND JAN2013 (WOODS) USED AS REFERENCE. HYDRANT LOCATIONS ANS SLICE VALUES ON SITE.


Standard: NZS4510- NZS4541 1978 1998 2008 SNZ-PAS-4509-2008

Hydrant Number	Static kPa	Location of site supply	Orifice size	Flow kPa	Flow meter	Ltr+/min	LITRES P-SEC	Comments/Work Required
1	750	BETWEEN BLD16 AND BLD1 RECEPTION/ BACKFLOW.SUPPLY.	D5	550	50	2310	38.5	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
2	750	OLD GARAGE WORKSOP.BLD4	D5	550	48	2262	37.7	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
3	750	RATA UNIT ,BLD8	D5	525	45	2196	36.6	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
4	750	I/D UNIT FRONT, POHUTOKAWA.BLD13	D5	525	45	2196	36.6	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
5	750	KAHIKATEA CARPARK. BLD9	D5	500	40	2070	34.5	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
6	750	ACCESS BRIDGE, RIMU.BLD14	D5	525	45	2196	36.6	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.
7	750	MEETING HOUSE, MARAE.BLD10	D5	500	50	2310	38.5	ACTION REQUIRED, POST/CAT EYE /TRIANGLE PAINTING.
8	760	REAR OF PURRI CTR. BLD12	D5	500	50	2310	38.5	ACTION REQUIRED, POST/ CAT EYE /TRIANGLE PAINTING.
9	750	POHUTOKAWA.BLD13	D5	500	48	2262	37.7	ACTION REQUIRED, CAT EYE /TRIANGLE PAINTING.

Disclaimer: IOP reserves the rights to withdraw Form 12a should the information provided by the owners, consultants or any third party are deemed to be incorrect. Form 12a shall be declared null and void.

Quok

# Appendix G – Existing Stormwater and Wastewater Utilities Plan



1050 dia. Wastewater transmission main

ESPLANADE RESERVE

375 dia. Public Wastewater main

Existing wastewater connection to be confirmed

225mm outfall to be upgraded

375 dia. Public Wastewater main (combined)

Existing 225 dia. stormwater main


11kV Vector cable and telecom ducts

50 dia. gas main (to Unitec?)


**EXISTING SERVICES ASSESSMENT**  
**AURECON MARK-UP**  
**01/03/2019**

**LEGEND**

- TELECOM SERVICE DUCTS
- COMMUNICATIONS SERVICE DUCTS
- POWER CABLES (LV) - BURIED DIRECT
- POWER CABLES (HV) - BURIED DIRECT
- GAS PIPE
- GAS PIPE (REDUNDANT)
- SANITARY SEWER PIPE
- SANITARY SEWER PIPE (PRIVATE)
- STORM WATER PIPE
- POWER SERVICE DUCTS
- LIGHTING SERVICE DUCT
- LIGHTING CIRCUIT
- FLEXALEN HOT WATER PIPE (F&R)
- MANHOLE
- LIGHTING COLUMN
- A= KIM LIGHTING - ARCHITYPE AR4 C/W 400W METAL HALIDE LAMP, TYPE IV REFLECTOR & 7m CSP PACIFIC OCLYTE BASE PLATE MOUNTED COLUMN
- B= UNKNOWN
- ELECTRICAL CHAMBER (1200x900)
- PC1-PC10 ELECTRICAL CHAMBER REFERENCE
- COMMUNICATIONS PIT (600x600)
- CC1-CC20 COMMUNICATIONS CHAMBER REFERENCE
- TELECOM'S CHAMBER (1200x900)
- TELECOM'S CHAMBER (Ø600)
- NEW MDPE PIPEWORK
- REDUNDANT WATER SUPPLY PIPEWORK.
- EXISTING WATER SUPPLY PIPEWORK
- FIRE HYDRANT
- SLUICE VALVE



SOUTHERN SITE (EXTENT NOT SHOWN)



NORTHERN SITE (EXTENT NOT SHOWN)

Issue	Description	Date	App'd
30.11.06			
05.12.06			
31.10.06			
The signing of this title block confirms the design and drafting of this project have been prepared and checked in accordance with the Maunsell assurance system certified to AS/NZS ISO 9001:2000			
Design	PDB	Checked	Date
Drawn	VPT		04.05.06
Approved			

This drawing is confidential and shall only be used for the purposes of this project.

Maunsell Limited  
AN AECOM COMPANY

Waitemata District Health Board  
Te Wai Auhina

**INTELLECTUAL DISABILITIES & KAUPAPA MAORI UNITS**  
**MASON CLINIC**  
 CARRINGTON RD AUCKLAND

**SITE & SERVICES PLAN (ENABLING WORKS)**

Scale  
 1 : 500 (A1)  
 1 : 1000 (A3)

Status  
 AS-BUILT  
 Drawing No. 3816035 - CS-00  
 Issue C

CAD Ref: J:\Depot\_23\60007086 - 102390028 Misc CAD Services\Mason Clinic as-builts\As-Built\_3816035-As-Built-00.dwg  
 Last saved: Thu, 30 Nov 2006 10:16 am  
 Copyright Maunsell Limited, 2003.

# Appendix H – Watercare Assessment Report 2021



**08 March 2021**

Waitemata District Health Board  
Private Bag 93-503  
Takapuna, Auckland 0740

Dear Nicola,

**Re: Your request for an assessment of water and wastewater capacity**

Address: **81A Carrington RD Mount Albert 1025**

Watercare application number **CON 60068**

This assessment is independent of the Auckland Council consenting process. This letter does not constitute a pre-approval from Watercare and the assessment is valid for two years from the date of this letter.

Watercare has undertaken an initial high-level assessment of the proposal for this **246 beds – Hospital/Mental Health Facility** at **81A Carrington RD Mount Albert**. Based on the information provided at this stage, in particular, AURECON calculations dated on 21/07/2020, we confirm the following.

**Water supply:** There is capacity in the local water supply network. Based on the supply only being an increase of approximately 6 l/s on currently demand and supply from Great South Road.

**Wastewater:** There are capacity constraints in the wastewater network. The developer shall undertake an asset investigation in order to further confirm these capacity constraints.

The 375mm diameter wastewater line extending through the site of the Mason Clinic development does appear to be at capacity for the incoming flow from the upstream catchment, due to its relatively flat grades. Watercare recommends carrying out an asset survey of these manholes, lid level and internal depth survey, to confirm its capacity. Be mindful that if the developer intends in the future to divert this section of the network, it would likely result in reduced grades further limiting capacity.

Wastewater network constraints will need to be mitigated by the developer through public network extensions or upgrades, depending on the agreed solution with Watercare as part of the resource consent process or future consent process.

Watercare Services Limited

Private Bag 94010

Auckland 2241

[www.watercare.co.nz](http://www.watercare.co.nz)

Customer service line

Mon to Fri 7.30 to 6pm

09 442 2222

[info@water.co.nz](mailto:info@water.co.nz)



Fault line

24 hours

09 442 2222

Free text 3130

[faults@water.co.nz](mailto:faults@water.co.nz)



375mm SS network with possible constraints (highlighted in orange) that requires asset investigation.

We are aware of a wider development on Unitec's site near this proposed development. In light of that, be aware that it might affect the final decision/outcome on the network in this area. This shall be assessed further in the future.

Yours Sincerely

**Tarso Giro**  
Development Engineer | Developer Services





**Document prepared by**

**Aurecon New Zealand Limited**

Level 4, 139 Carlton Gore Road  
Newmarket Auckland 1023  
PO Box 9762  
Newmarket Auckland 1149  
New Zealand

**T** +64 9 520 6019

**F** +64 9 524 7815

**E** [auckland@arecongroup.com](mailto:auckland@arecongroup.com)

**W** [arecongroup.com](http://arecongroup.com)

**aurecon**

*Bringing ideas  
to life*

